FORM 13
(See Rule 65 And 73-A)
REPORT OF EXAMINATION OF PRESSURE PLANT / VESSEL / GAS HOLDER

Report No:CRT/SOPL/04-2025/12

1.	Name and address of the Factory	:	SHIVAM OXYGEN PRIVATE LIMITED 577, Nadai Village, Murbad Taluka, Dist. - Thane.
2.	Name, Description and distinctive number of Pressure Plant /Vessel/ Gas Holder	:	Ammonia Scrubber Size : 0.52 Dia. x 0.80 meter Ht., Material : M.S.
3.	Name and address of maker	:	M/s. Locally Fabricated
4.	Nature of process in which Pressure Plant/Vessel is used.	:	To Remove Moisture from Acetelene Gas.
5.	Particulars of Plant/Vessel-	:	
	(a) Date of Construction	:	2003
	(b) Thickness of Wall	:	Dish : 8.0 mm, Shell : 8.0 mm
	(c) Date on which it was first taken into use	:	2003
	(d) Safe working pressure recommended by maker	:	5.00 Kg/cm2
A.	Particulars of Plant/ Vessel/ Gas Holder	:	
	a. Parts of the gas – holders examined by electronics or other accurate devices or by cutting sample discs and results thereof.	:	Not applicable
	b. Particulars as to the condition of.	:	Not applicable
	i) Crown.	:	Not applicable
	ii) Side sheeting including grips and cups.	:	Not applicable
	ii) Side sheeting including grips and cups.	:	Not applicable
	iii) Guiding mechanism (roller carriages, roller, pins, guide, ropes, etc.)	:	Not applicable
	iv) Tank	:	Not applicable
	v) Other structure, if any, columns (framing and bracking).	:	Not applicable
	c. Particulars as to the position of the lift at the time of examination.	:	
		:	
	d. Particulars as to whether the tank and lifts were found sufficiently level for safe working.	:	
6.	Date of -	:	
	i) Last External Examination	:	02.10.2024
	ii) Last internal examination	:	Inaccessible
	iii) Last hydraulic examination	:	---------
	iv) Last ultrasonic test	:	02.10.2024
A.	By whom it is carried out?	:	Sayyad V A (C P C No. S - 085 / 2024)
7.	Whether lagging was removed for purpose of examination	:	Not lagging
8.	Description of examinations carried out and findings	:	-------
	i) External Examination (Give reasons if it is not carried out six monthly)	:	Done & Found O.K.
	ii) Internal Examination (Give reasons if it is not carried out annually)	:	Inaccessible
	iii) Hydraulic Test (Give reasons if this is not carried out at interval of 2 years or 4 years.)	:	Not Offered
	iv) Ultrasonic Test (Please quote number and date of the certificate issued by Chief Inspector, permitting ultrasonic test in lieu of internal examination and hydraulic test)	:	Dish 1 : 7.60 m.m. Dish 2 : 7.70 m.m. Shell : 7.80 m.m.
9.	Safe Working Pressure calculated as per methods given in sub rule 5 (c) (ii) for sizing cylinders- (1) (2) (3)	:	Not applicable as it is not Sizing Cylinder
10.	Condition of Pressure Plant	:	
	a) Vessel	:	OK
	b) Piping	:	OK
11.	Conditions of fittings and appliances	:	
	i) Pressure Gauges	:	Found Okay (Range 0 - 2.10 Kg/cm2)
	ii) Safety Valves	:	Found Okay (Set at 7.0 Kg/cm2)
	iii) Stop Valve	:	Found Okay
	iv) Reducing Valves (give reasons if not necessary)	:	Not applicable
	v) Additional safety valve (required in case reducing valve is necessary)	:	Not applicable
	vi) Other devices (Please specify particularly in case of Jacketed vessels)	:	Nil
	vii) Are all fittings and appliances properly maintained and in good condition, repairs if any required and period within which they should be execute.	:	Condition of L. P. Drier found Satisfactory. No repairs.
12.	Safe working pressure recommended after examination (specify the allowances made for condition of working such as heat, corrosion etc.)	:	5.00 Kg/cm2
13.	Specify repairs if any and period within which they should be executed	:	No repairs.
14.	Specify reduced working pressure pending repairs	:	No reduction in pressure
15.	Other observations /conditions subject to which the plant is to be operated	:	Nil

I/We certify that on **10.04.2025** the pressure plant / vessel described above was thoroughly cleaned and (so far as its construction permits) made accessible for thorough examination and for such tests as were necessary for thorough examination and that on the said date. I thoroughly examined this pressure vessel/Plant including its fittings and that the above is true report of my examination.

Next Due Date: 09.10.2025

Signature of Competent Person :



Name of Competent Person : Sayyad Vahid Ali

Qualification : DME, ADIS

Address : Mumbai : 113, Blossom Commercial Bldg., Raheja Complex, Kalyan(West), Dist. Thane. Maharashtra 421301 Nashik : 02, Shri Sai Apartment, Pakhal Road, Dwarka, Nashik 422011



FORM 13
(See Rule 65 And 73-A)
REPORT OF EXAMINATION OF PRESSURE PLANT / VESSEL / GAS HOLDER

Report No:CRT/SOPL/04-2025/13/1

1.	Name and address of the Factory	:	SHIVAM OXYGEN PRIVATE LIMITED 577, Nadai Village, Murbad Taluka, Dist. - Thane.
2.	Name, Description and distinctive number of Pressure Plant /Vessel/ Gas Holder	:	L. P. Drier No. 2 Material : M.S., Size : 0.4 Dia. x 1.45 meter Ht.
3.	Name and address of maker	:	M/s. Locally Fabricated
4.	Nature of process in which Pressure Plant/Vessel is used.	:	To Remove Moisture from Acetelene Gas.
5.	Particulars of Plant/Vessel-	:	
	(a) Date of Construction	:	2003
	(b) Thickness of Wall	:	Dish : 8.0 mm, Shell : 8.0 mm
	(c) Date on which it was first taken into use	:	2003
	(d) Safe working pressure recommended by maker	:	5.00 Kg/cm2
A.	Particulars of Plant/ Vessel/ Gas Holder	:	
	a. Parts of the gas – holders examined by electronics or other accurate devices or by cutting sample discs and results thereof.	:	Not applicable
	b. Particulars as to the condition of.	:	Not applicable
	i) Crown.	:	Not applicable
	ii) Side sheeting including grips and cups.	:	Not applicable
	ii) Side sheeting including grips and cups.	:	Not applicable
	iii) Guiding mechanism (roller carriages, roller, pins, guide, ropes, etc.)	:	Not applicable
	iv) Tank	:	Not applicable
	v) Other structure, if any, columns (framing and bracking).	:	Not applicable
	c. Particulars as to the position of the lift at the time of examination.	:	
		:	
	d. Particulars as to whether the tank and lifts were found sufficiently level for safe working.	:	
6.	Date of -	:	
	i) Last External Examination	:	02.10.2024
	ii) Last internal examination	:	Inaccessible
	iii) Last hydraulic examination	:	---------
	iv) Last ultrasonic test	:	02.10.2024
A.	By whom it is carried out?	:	Sayyad V A (C P C No. S - 085 / 2024)
7.	Whether lagging was removed for purpose of examination	:	Not lagging
8.	Description of examinations carried out and findings	:	-------
	i) External Examination (Give reasons if it is not carried out six monthly)	:	Done & Found O.K.
	ii) Internal Examination (Give reasons if it is not carried out annually)	:	Inaccessible
	iii) Hydraulic Test (Give reasons if this is not carried out at interval of 2 years or 4 years.)	:	Not Offered
	iv) Ultrasonic Test (Please quote number and date of the certificate issued by Chief Inspector, permitting ultrasonic test in lieu of internal examination and hydraulic test)	:	Dish 1 : 7.60 m.m. Dish 2 : 7.70 m.m. Shell : 7.80 m.m.
9.	Safe Working Pressure calculated as per methods given in sub rule 5 (c) (ii) for sizing cylinders- (1) (2) (3)	:	Not applicable as it is not Sizing Cylinder
10.	Condition of Pressure Plant	:	
	a) Vessel	:	OK
	b) Piping	:	OK
11.	Conditions of fittings and appliances	:	
	i) Pressure Gauges	:	Found Okay (Range 0 - 2.10 Kg/cm2)
	ii) Safety Valves	:	Found Okay (Set at 7.0 Kg/cm2)
	iii) Stop Valve	:	Found Okay
	iv) Reducing Valves (give reasons if not necessary)	:	Not applicable
	v) Additional safety valve (required in case reducing valve is necessary)	:	Not applicable
	vi) Other devices (Please specify particularly in case of Jacketed vessels)	:	Nil
	vii) Are all fittings and appliances properly maintained and in good condition, repairs if any required and period within which they should be execute.	:	Condition of L. P. Drier found Satisfactory. No repairs.
12.	Safe working pressure recommended after examination (specify the allowances made for condition of working such as heat, corrosion etc.)	:	5.00 Kg/cm2
13.	Specify repairs if any and period within which they should be executed	:	No repairs.
14.	Specify reduced working pressure pending repairs	:	No reduction in pressure
15.	Other observations /conditions subject to which the plant is to be operated	:	Nil

I/We certify that on **10.04.2025** the pressure plant / vessel described above was thoroughly cleaned and (so far as its construction permits) made accessible for thorough examination and for such tests as were necessary for thorough examination and that on the said date. I thoroughly examined this pressure vessel/Plant including its fittings and that the above is true report of my examination.

Next Due Date: 09.10.2025

Signature of Competent Person :

Name of Competent Person : Sayyad Vahid Ali

Qualification : DME, ADIS

Address : Mumbai : 113, Blossom Commercial Bldg., Raheja Complex, Kalyan(West), Dist. Thane. Maharashtra 421301 Nashik : 02, Shri Sai Apartment, Pakhal Road, Dwarka, Nashik 422011

CREATIVE SERVICES

FORM 13
(See Rule 65 And 73-A)
REPORT OF EXAMINATION OF PRESSURE PLANT / VESSEL / GAS HOLDER

Report No:CRT/IE/03-2025/13/1

1.	Name and address of the Factory	:	INDUSTRIAL ENGINEERS Plot No. C - 4, M.I.D.C., Anand Nagar, Additional Ambernath Indl. Area, Ambernath (E), Dist - Thane
2.	Name, Description and distinctive number of Pressure Plant /Vessel/ Gas Holder	:	Horizontal Air Receiver of Compressor Sr. No. : A 111 93, Cap. 9.40 Cufit.
3.	Name and address of maker	:	Sonee
4.	Nature of process in which Pressure Plant/Vessel is used.	:	For Storage & Supply of Compressed Air.
5.	Particulars of Plant/Vessel-	:	
	(a) Date of Construction	:	2011
	(b) Thickness of Wall	:	Dish : 3.0 mm, Shell : 3.0 mm
	(c) Date on which it was first taken into use	:	2012
	(d) Safe working pressure recommended by maker	:	5.70 Kg/cm2
A.	Particulars of Plant/ Vessel/ Gas Holder	:	Not applicable
	a. Parts of the gas – holders examined by electronics or other accurate devices or by cutting sample discs and results thereof.	:	Not applicable
	b. Particulars as to the condition of.	:	Not applicable
	i) Crown.	:	Not applicable
	ii) Side sheeting including grips and cups.	:	Not applicable
	ii) Side sheeting including grips and cups.	:	Not applicable
	iii) Guiding mechanism (roller carriages, roller, pins, guide, ropes, etc.)	:	Not applicable
	iv) Tank	:	Not applicable
	v) Other structure, if any, columns (framing and bracking).	:	Not applicable
	c. Particulars as to the position of the lift at the time of examination.	:	Not applicable
		:	
	d. Particulars as to whether the tank and lifts were found sufficiently level for safe working.	:	Not applicable
6.	Date of -	:	
	i) Last External Examination	:	25.09.2024
	ii) Last internal examination	:	Inaccessible
	iii) Last hydraulic examination	:	17.01.2013
	iv) Last ultrasonic test	:	25.09.2024
A.	By whom it is carried out?	:	Sayyad V A (C P C No. S - 085 / 2024)
7.	Whether lagging was removed for purpose of examination	:	Not lagging
8.	Description of examinations carried out and findings	:	-------
	i) External Examination (Give reasons if it is not carried out six monthly)	:	Done & Found O.K.
	ii) Internal Examination (Give reasons if it is not carried out annually)	:	Inacessable
	iii) Hydraulic Test (Give reasons if this is not carried out at interval of 2 years or 4 years.)	:	Not Offered
	iv) Ultrasonic Test (Please quote number and date of the certificate issued by Chief Inspector, permitting ultrasonic test in lieu of internal examination and hydraulic test)	:	Tested & minimum thickness observed Dish 1 : 2.80 m.m. Dish 2 : 2.90 m.m. Shell : 2.90 m.m.
9.	Safe Working Pressure calculated as per methods given in sub rule 5 (c) (ii) for sizing cylinders- (1) (2) (3)	:	Not applicable as it is not Sizing Cylinder
10.	Condition of Pressure Plant	:	
	a) Vessel	:	OK
	b) Piping	:	OK
11.	Conditions of fittings and appliances	:	
	i) Pressure Gauges	:	Found Okay (Range 0 - 21.0 Kg/cm2)
	ii) Safety Valves	:	Found Okay
	iii) Stop Valve	:	Found Okay
	iv) Reducing Valves (give reasons if not necessary)	:	Not applicable
	v) Additional safety valve (required in case reducing valve is necessary)	:	Not applicable
	vi) Other devices (Please specify particularly in case of Jacketed vessels)	:	Nil
	vii) Are all fittings and appliances properly maintained and in good condition, repairs if any required and period within which they should be execute.	:	Condition of Air Receiver found Satisfactory. No repairs.
12.	Safe working pressure recommended after examination (specify the allowances made for condition of working such as heat, corrosion etc.)	:	Not applicable
13.	Specify repairs if any and period within which they should be executed	:	Nil
14.	Specify reduced working pressure pending repairs	:	Nil
15.	Other observations /conditions subject to which the plant is to be operated	:	Nil

I/We certify that on **25.03.2025** the pressure plant / vessel described above was thoroughly cleaned and (so far as its construction permits) made accessible for thorough examination and for such tests as were necessary for thorough examination and that on the said date. I thoroughly examined this pressure vessel/Plant including its fittings and that the above is true report of my examination.

Next Due Date: 24.09.2025

Signature of Competent Person :

Name of Competent Person	:	Sayyad Vahid Ali
Qualification	:	DME, ADIS
Address	:	Mumbai : 113, Blossom Commercial Bldg., Raheja Complex, Kalyan(West), Dist. Thane. Maharashtra 421301 Nashik : 02, Shri Sai Apartment, Pakhal Road, Dwarka, Nashik 422011

CREATIVE SERVICES